

Note: For Fort Hood Department Requirement. Replace para. 1.2.3 Keys and Locks in Guide Specificaliton 13851 with the following paragraph.

All locks shall be CAT-15 keyed except that the fire alarm transmitter shall remain factory keyed.