



SCALE: 1/2" = 1'-0"
 2' 1' 0' 2'
 SCALE: 1/2" = 1'-0"

GENERAL NOTES:

1. ALL CONDUIT IS 1/2" RIGID UNLESS OTHERWISE STATED.
2. CONDUCTORS SHALL NOT BE SPLICED IN ROOM J-BOXES.
3. PULL BOXES AND CONDULETS IF INSTALLED SHALL HAVE TAMPER SWITCHES OR HAVE COVERS SPOT WELDED.
4. SHUT DOOR FRAME AS REQUIRED TO FACILITATE MOUNTING OF SWITCH ASSEMBLY AS SHOWN IN ORIENTATION DETAIL.
5. CONDUIT RUNS SHOWN BETWEEN SYSTEM COMPONENTS ARE SCHEMATIC ONLY.
6. GFCI INDICATES GOVERNMENT FURNISHED, CONTRACTOR INSTALLED.
7. GFCI INDICATES CONTRACTOR FURNISHED, CONTRACTOR INSTALLED.

KEYED NOTES:

- ① CONTROL UNIT (GFCI) MOUNTED 54" AFF.
- ② PASSIVE INFRARED SENSOR, MOUNTED SUCH THAT BOTTOM OF UNIT IS 8'-0" AFF. (GFCI)
- ③ BALANCED MAGNETIC SWITCH ASSEMBLY (GFCI)
- ④ BALANCED MAGNETIC SWITCH ACTUATING MAGNET (GFCI)
- ⑤ DURESS SWITCH (GFCI) MOUNTED 60" AFF.
- ⑥ GFCI CONDUIT WITH GFCI CABLE, COIL UP 18" SLACK CABLE AT EACH END, GOVERNMENT WILL TERMINATE CABLES.
- ⑦ KEYPAD (GFCI) MOUNTED 54" AFF.
- ⑧ PASSIVE INFRARED SENSOR (GFCI) CEILING MOUNTED.

THIS INFORMATION IS BASED ON ICIDS-II REQUIREMENTS. SYSTEM TO BE USED NEEDS TO BE VERIFIED WITH PHYSICAL SECURITY.