

NOTE: For Fort Hood to provide compatibility between radio transmitters and receiver at fire station. Replace para. 2.8.1 Radio Transmitters in CEGS 13851 with the following para.

The proprietary supervising station receiving equipment is Monaco D-700 operating at 139.675 Mhz and the transmitter shall be fully compatible with this equipment. Each radio alarm transmitter shall be the manufacturer's recognized commercial product, completely assembled, wired, factory tested, and delivered ready for installation and operation. Transmitters shall be provided in accordance with applicable portions of NFPA 72, NFPA 1221, and 47 CFR 15. Transmitter electronics module shall be contained within the physical housing as an integral, removeable assembly. Contractor shall load appropriate coding numbers at the time of final inspection.